

Summary of results collected by MDE in Emmitsburg's distribution system (and at the water treatment plant) on  
1/29/2020

	Iron (ppm)	Manganese (ppm)	Lead (ppm)	Turbidity (NTU)	total coliform bacteria (MPN/100 ml)	<i>E. coli</i>
126 E Main St	<0.100	<0.050	<0.005	<0.5	<1	<1
527 W. Main St	<0.100	<0.050	<0.005	<0.5	<1	<1
1330 Wheatley Dr.	<0.100	<0.050	<0.005	<0.5	<1	<1
Hydrant, 17700 Creamery Rd. @ pump station	<0.100	<0.050	<0.005	<0.5	not tested	not tested
Hydrant, intersection of Timbermill Ct. & Wheatley Dr.	0.140	<0.050	<0.005	2.2	not tested	not tested
Water Treatment Plant	<0.100	<0.050	<0.005	<0.5	<1	<1
"<" indicates that the parameter was not detected above the detection limit						